

108050000-TD8020-R00

Spallation Neutron Source

Ring Service Building Compressed Air Controls Functional System Design (FSD)

January, 2003



A. E. Claver 3/3/03
SNS Project Engineer



A U. S. Department of Energy Multilaboratory Project

SPALLATION NEUTRON SOURCE

Argonne National Laboratory • Brookhaven National Laboratory • Lawrence Berkeley National Laboratory • Los Alamos National Laboratory • Oak Ridge National Laboratory

Ring Service Building Compressed Air Controls Description
TD8020 Rev 0, January 13, 2003

Operating Philosophy

Purpose:

The purpose of the compressed air system operation is to:

- a) Provide an operator indication of the air pressure on the compressed air header in the Ring and RTBT building.

NOTE: The Ring and RTBT compressed air header pressures will be displayed on the Ring Building Overview Display screen and HEBT/RTBT Building Overview Display screen respectively.

Assumptions:

None

Operator Controls and Operating Modes

None

OPERATOR INTERFACE DEFINITIONS

Local Hardware/Manual Operator Controls

None

Software HMI/EPICS Digital Operator Controls

None

Software HMI/EPICS Digital Displays

None

Software HMI/EPICS Analog Operator Controls

None

Software HMI/EPICS Analog Displays

- 1) Ring compressed air header pressure (*PT6600*)
- 2) RTBT compressed air header pressure (*PT6800*)

Alarms

None

Control Logic Description

None