

STATUS OF THE ALBA CONTROL SYSTEM

D. Fernández-Carreiras on behalf of the controls groups. CELLS-Consortium for the Construction, equipment and Exploitation of a Synchrotron light source laboratory. PO Box 68, 08193 Bellaterra, Spain.

Abstract

Alba [1] is a synchrotron light source located in the Barcelona area and co-financed by the Spanish and Catalan governments. This 3 GeV third generation light source is planned to deliver the first X-rays beam to the users in 2010. This paper describes the progress in the design of the control system for the machine and beamlines. Hardware and Software solutions are presented. Ethernet, PCI and Linux are extensively used. Servers are mostly written Python and C++, whereas clients are most Python and Java. Solutions for interfacing devices, networking, interlocks, diagnostics are presented.



Figure 1: View of the progress of the works. Picture taken on the 1st of September 2007.

INTRODUCTION

The construction of ALBA, the 3 GeV Synchrotron Light Source near Barcelona (Spain) is proceeding according to schedule. Although the building will be finished on June 2008, the preparation and installation of the components for the Linac is foreseen in November 2007. The 100 MeV Linac is manufactured by Thales Communication as a turnkey system. The 3GeV booster and the storage ring are installed in the same tunnel.

The architecture of the control system is distributed. Boot servers and Tango [2] databases and archivers run on boxes in the computing room. Tango servers run in IOCs (Input Output Controllers) which are linux boxes, most of them diskless. Compact PCI crates are installed in all those devices where a timing event receiver is needed. The remaining ones are Industrial PCs. Beamlines have industrial PCs with disk.

SUBSYSTEMS

Linac

The 100 MeV Linac is manufactured by Thales Communication as a turnkey system. Nevertheless the control system is based on PLCs with 2 interfaces based on a common library. One of the interfaces is for local control, intended to be used for commissioning. It is delivered with the system, and the other one connects to the ALBA control system allowing the use of common tools for archiving, save and restore, and intercommunications.

RF

The storage ring has six radio frequency plants with a power of 160 kW (two transmitters of 80 kW each) The booster has another plant of 80 kW. Pulses in the electron gun are chopped at 499.654 Mhz. A transmitter including a high voltage power supply (HVPS) and a Inductive Output Tube (IOT) have been already installed in the Radiofrequency lab. The control system for the transmitter is based on Siemens Programmable Logic Controllers (PLCs) and delivered by Thomsom. The interlock system follows the same philosophy as the general Equipment Protection System (EPS) and uses B&R PLCs with CPUs installed in cabinets outside the tunnel and distributed I/O modules inside the tunnel. Both are interconnected through an X20 bus. Graphical interfaces are written in Python [3] and Qt4 [4]




Figure 2: Graphical user interface of the for the low level analogue regulation of the RF. It is written in Python and Qt4.

The PSS interlocks every RF transmitter (out of 13) in two different ways as well as both klystrons of the Linac and the electron gun. It has been designed to be SIL3 compliant.

Beamlines

A project for writing a generic tool for beamline control has been started at Alba, and now the European Synchrotron Radiation Facility (ESRF) is collaborating in the development. This “device pool” provides a common way of acquiring data, moving motors, scanning and in general interfacing any device. It is based on Tango, written in C++ and Python. This is very appropriate for beamline controls, diffractometers, detectors, motors, counters, etc. but also for some applications in the accelerator controls. For example, scanning scrappers or power supplies like in the case of the measurement of emittances, etc. Figure 6 shows one configuration panel of the device pool.



Figure 6: Configuration tool of the “device pool”

Motion control

Alba uses Icepap as the standard motor controller. The Icepap electronics is a development of the ESRF. It is presented in crates of 8 power drives and a controller which can be a master or a slave. It is fully configurable by software and accessed by Ethernet or serial lines. The configuration and test tool is an application written at Alba using python and Qt4. Icepaps are used at the beamlines as well as in the insertion devices, scrappers, and RF cavity plunger.

SOFTWARE

Computers in the server room, operator consoles, and IOCs use Suse10.2 linux distribution as the current standard. Python 2.5 and Qt4 are also being adopted. Applications are packaged using Red hat Package Manager (RPM), and deployed using blissinstaller and blissbuilder [8]. Those are a couple of tools for building

and later installing packages, and keeping track of the versions of the packages and where they have been installed.

ARCHITECTURE

Ethernet is widely used by the control electronics. Power supplies, Liberas, CCD cameras, Oscilloscopes, and of course IOCs are connected by Ethernet. Most IOCs get a dynamic address by Dynamic Host Configuration Protocol (DHCP). Few VLANS (Virtual Local Area Networks) are defined. The main control, EPS, liberas, power supplies and diagnostics are separated into different VLANS as most communications are between devices of the same group.

The Tango database and databases for archivers (mysql) reside in linux boxes in the computing room whereas fast data loggers for RF and eventually vacuum will store data online.

CONCLUSION

Major choices like Ethernet as field bus, PCI and cPCI, Liberas, Icepaps, Linux and Tango have been taken. Prototypes have already been implemented mostly for the RF lab which needs an RF control, EPS, Vacuum control, Archivers, Save/Restore, and even a PSS. Choices up to now demonstrated to fulfil all the needs and expectations. However, Large scale systems need still to be tested, in particular for the archiver and tango databases.

ACKNOWLEDGEMENTS

Many developers are working or have worked in this project. Besides the computing division at Alba, I would like to thank specially E.Taurel, A.Homs, M.Guijarro, and V.Rey from the ESRF. Also special thanks to the Tango collaborators who have written most of the standard Tango Applications and Tools available for the community: ESRF, Soleil and Elettra. Recently Hasylab has also joined the community.

REFERENCES

- [1] <http://www.cells.es>
- [2] <http://www.tango-controls.org>
- [3] <http://python.org>
- [4] <http://trolltech.com>
- [5] <http://www.i-tech.si>
- [6] D. Einfeld et al. “Status of the Alba project”, PAC’07. Albuquerque, June 2007. p. 1073.
- [7] D. Beltran et al. “Initial design of the global fast orbit feedback for the Alba synchrotron”, These procedures.
- [8] <http://esrf.eu/UsersAndScience/Experiments/TBS/BLISS>